

TENAFLY FIRE DEPARTMENT
Borough of Tenafly
100 Riveredge Road, Tenafly, NJ 07670

Bureau of Fire Prevention
Wm. Kent Yates, FIRE OFFICIAL

201-568-9269

PROPANE TANK PERMIT REQUIREMENTS

- 1) Propane Tanks cannot be refilled on property.
- 2) Propane Tanks must be chained to something to prevent tanks from fling over.
- 3) Propane Tanks must be set up outside the buildings. They must be at least ten (10) feet from the building.
- 4) No one except members of your staff can be in the area where the tanks are placed.
- 5) When will the Propane Tanks be brought to the site and removed?
- 6) What are the sizes of the Tanks? Are they larger than 1 gallons (water capacity)? If larger, then there will be further restrictions.
- 7) Propane Tanks must be closed when not in use.